


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	ACG-100 Double Hung Window	ACG-100 Double Hung Window	800 Pa Rating: N4 (General) N3 (Corner windows)	2000 Pa Rating: N4 (General) N3 (Corner windows)	No water penetration at: 300 Pa. (Water penetration occurred at the joint between operable sash bottom rail and frame after spraying for 2 mins at 450Pa.) Rating: N5 (Non-exposed) N4 (Exposed)	At +75Pa 4.02 L/s m ² At -75Pa 4.35 L/s m ² Rating: High	10 March 2022 Test Report No. 220223081GZU-003
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		1206 mm (Width) x2060mm (Height) x 118 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 1230mm (Width) x 1030 mm (Height) x 50mm (Thickness); Fixed Sash: 1230mm (Width) x 1030 mm (Height) x 50mm (Thickness)					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2*25 & Aluminium Connector: 50*50*30*T4.					
Hardware:		Specify type: Double Hung, Model: UXC100, Supplier: CALDWELL.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 3					
Gasket (between the sash and the frame)		Materials: EPDM, Supplier: HAIDA;					
Thermal break:		Model: C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
Certification Issue Date: 20 July 2025
Certification Expiry Date: 19 July 2026
CSI Schedule Number: CSI Lic 7676-2025-07-S4-R0

Certification Review Date: 4 June 2025
Next Annual Review Date: 15 June 2026
CSI Database ID Number: 1000413


Azma Khan
Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.