


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	ACG100 -100 Sliding Door	ACG100 - 100 Sliding Door	600 Pa Rating: N3 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 200 Pa. (Water kept splashing into interior from the joint of the aluminum profile and door sash at sliding sash side when spraying at 300Pa.) Rating: N4 (Non-exposed) N3 (Exposed)	At +75Pa 1.24 L/s m ² At -75Pa 1.45 L/s m ² Rating: High	2022/4/7 Test Report No. 220223081GZU-004
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		5400 mm (Width) x 2650mm (Height) x 118 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: Operable Sash: 1350(Width) x 2550mm (Height) x 40mm(Thickness), QTY: 2; Fixed Sash:1350 (Width) x 2550mm(Height) x 40mm(Thickness), QTY: 2;					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2 * 35.					
Hardware:		Model: ZCDG421-1500 & ZTLS1320 & ZMHL4410, Supplier: KINLONG.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 15					
Gasket (between the sash and the frame)		Materials: EPDM, Supplier: HAIDA;					
Thermal break:		Model: C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S5-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.